

NOTES FOR STAIR CONDITION:

USE SUPPLIED ACUTE ANGLE BRACKET AT TOP OF STAIR RUN WITH 2-#10X1 1/2" SCREWS TO RAIL, AND 2-#10X1 1/2" SCREWS TO POST.

USE SUPPLIED OBTUSE ANGLE BRACKET AT BOTTOM OF STAIR RUN WITH 2-#10X1" SCREWS TO RAIL, AND 2-#10X1 1/2" SCREWS TO POST.



ALTHOUGH THE TEST REPORT PERIOD HAS EXPIRED, WE ASSUME THERE ARE NO CHANGES TO THE ASSEMBLY.

NATIONAL BUILDING CODE - 2019 ALBERTA EDITION REQUIREMENTS

9.8.8.3 Height of Guards

- 1) Except as provided in Sentences (2) to (4), all guards shall be not less than 1070MM (3ft 6 in) high.
- (2) All guards within dwelling units shall be not less than 900 mm (2 ft 11in) high.
- (3) Exterior guards serving not more than one dwelling unit shall be not less than 900 mm (2 ft 11in) high where the walking surface served by the guard is not more than 1800 mm (5 ft 11 in) above the finished ground level.
- (4) Guards for flights of steps, except in required exit stairs, shall be not less than 900 mm (2 ft 11 in) high.
- (5) The height of guards for flights of steps shall be measured vertically from the top of the guard to a line drawn through the tread nosing served by the guard.

9.8.8.5. Openings In Guards

- (1) Except as provided in Sentence (2) and (3), openings through guards shall be of a size that will prevent the passage of a spherical object having a diameter of 100 mm (4 in).

Refer to TimberTech Installation Guide for additional installation information.


This document is valid for one year from issue date. It may be renewable on an annual basis. Our ABC compliance calculations compared data obtained from: Architectural Testing Reports: Architectural Testing Reports No.A9084.01-119-19 dated OCT.07-2011.

NATIONAL BUILDING CODE 2019 ALBERTA EDITION REQUIREMENTS PART 9 - RESIDENTIAL USE (FROM Table 9.8.8.2 Specified Loads for Guards)	INTERTEK/ARCHITECTURAL TESTING COMPLIANCE REFERENCE (Test Series No. & Condition)
Horizontal Load Applied Inward or Outward at any Point at the Minimum Required Height of the Guard: 0.75 kN/m (52 lb/ft) or concentrated load of 1.0 kN (224 lb) applied at any point	Test Series No.1 (In-Line Condition) Test Series No.2 (45° Condition) Test Series No.3 (Stair Condition)
Horizontal Load Applied Outward on Elements Within the Guard, Including Solid Panels and Balusters: Concentrated load of 0.5 kN (112 lb) applied over an area of 100mm by 100mm at any point on the element or elements so as to produce the most critical effect	Test Series No.1 (In-Line Condition) Test Series No.2 (45° Condition) Test Series No.3 (Stair Condition)
Evenly Distributed Vertical Load Applied at the Top of the Guard: 1.5 kN/m (103 lb/ft)	Test Series No.1 (In-Line Condition) Test Series No.2 (45° Condition) Test Series No.3 (Stair Condition)

0	OCT 15/19	ISSUED FOR A.B.C COMPLIANCE
REVISION	DATE	DESCRIPTION
CLIENT: CPG BUILDING PRODUCTS 894 PRARIE AVENUE WILMINGTON, OHIO 45177		
NOM DU PROJET: INTERTEK/ARCHITECTURAL TESTING PROJECT NAME: ALBERTA BUILDING CODE COMPLIANCE		
TITRE: RADIANCE RAIL EXPRESS SYSTEM		
BY: B.K.	CHECKED: J.S.	SCALE: AS NOTED
DATE: JAN.21/13		
PROJECT NO.: BD2019-10-15	BD-TT-RRE-04	

Radiance Rail Express System

3/4" = 1'-0"



Bryte Designs

51A UNDERHILL DRIVE, SUITE # 210
TORONTO, ON M3A 2J8
TEL: 416-638-1932
FAX: 416-638-7305